



"Maji Safi Maisha Bora"
"Quality Water Healthy Livelihood"

ADDENDUM

Kakamega County Water and Sanitation company(KACWASCO) wishes to notify bidders participating in the tender below that there are amendments on the tender document which has been deemed necessary, calling for an addendum to the tender

Description Tender Name	Tender No.	Original Closing Date	New Closing Date	Bids Available from	Post or deliver bids to
Tindinyo Small Works Water Project	KACWASCO/TECH/06/2022-2023	Monday 28th November 2022 at 11:00 hrs East African Time	Monday 5TH December 2022 at 11:00 hrs East African Time	The company website: www.kakamegawater.co.ke	The Ag. Chief Executive Officer Kakamega County Water and Sanitation Company P.O.Box 1189-50100 Kakamega, Kenya Tel: 056-2030355 Email To: kacwasco@gmail.com

TINDINYO WATER TREATMENT PLANT REHABILITATION WORKS SPECIFICATION AND BOQ ADDENDUM

		Initial				Reviewed					
No.	Item		Specification	Unit	Quantity		Amount	Unit	Quantity	Rate	Amount
1.	Preliminaries and General	A.1	Allow for contractor's mobilizing staff and equipment to site, site	LS	1	A.1	Allow for contractor's mobilizing staff and equipment to site, site	LS	1		

	Items		clearance, provision of facilities to run the camp and maintaining the camp throughout the construction period and demobilizing after the completion of the works. Include for temporary access and land requirement by contractor as directed by the engineer.				clearance, provision of facilities to run the camp and maintaining the camp throughout the construction period and demobilizing after the completion of the works. Include for temporary access and land requirement by contractor as directed by the engineer.				
		A. 2	Allow for cost of supervision of the works by KACWASCO staff including fuel, meals and other administrative costs.	LS	1	A. 2	Allow for cost of supervision of the works by KACWASCO staff including fuel, meals and other administrative costs.	LS	1		
			Sub - total								
2.	Rotork gears.	2.0	Provide for supply, installation, testing and commissioning of rotork gears of the following specifications.			2.0	Provide for supply, installation, testing and commissioning of rotork gears of the following specifications.				
		2.1	Quarter turn worm rotork gears AB550N	No.	12	2.1	Quarter turn worm rotork gears AB550N	No.	8		
		2.2	Quarter turn worm rotork gears AB55N	No.	10	2.2	Quarter turn worm rotork gears AB880N	No.	22		
			Sub - total								
3.	Chemical dosers.	3.0	Provide for supply, installation, testing and commissioning of chemical dosers of the following			3.0	Provide for supply, installation, testing and commissioning of chemical dosers of the				

			specifications.				following specifications.			
		3.1	Gravity dosing system 100/800 L/H.	Pc.	2	3.1	Gravity dosing system 100/800 L/H.	Pc.	4	
		3.2	Gravity dosing system 200/1800 L/H.	Pc.	4	3.2	Gravity dosing system 200/1800 L/H.	Pc.	2	
		3.3	Flow meter 0-100L/H PVC OD 32mm with two unions	Pc.	2	3.3	Flow meter 0-100L/H PVC OD 32mm with two unions	Pc.	4	
		3.4	Flow meter 100-1000 L/H PVC OD 32mm with two unions.	Pc.	4	3.4	Flow meter 100-1000 L/H PVC OD 32mm with two unions.	Pc.	2	
			Sub - total							
4.	Chemical Stirrers.	4.1	Provide for supply, installation, testing and commissioning of electric powered stirrers, vertical mount motor rating – Single phase 220v, 1.1KW, 910rpm, 50Hz, directly coupled to stainless stirring shaft, and stainless stirrer cross blade.	No.	2	4.1	Provide for supply, installation, testing and commissioning of electric powered stirrers, vertical mount motor rating – Three phase 415v, 1.1KW, 910rpm, 50Hz, directly coupled to stainless stirring shaft, and stainless stirrer cross blade.	No.	2	
		4.2	Provide for supply, installation, testing and commissioning of electric powered stirrer, vertical mount motor rating – Single phase 220v, 1.5KW, 910rpm, 50Hz, directly coupled to stainless stirring shaft, and stainless stirrer cross blade.	No.	4	4.2	Provide for supply, installation, testing and commissioning of electric powered stirrer, vertical mount motor rating – Three phase 415v, 1.5KW, 940rpm, 50Hz, directly coupled to stainless stirring shaft, and stainless	No.	2	

							stirrer cross blade.				
		-	-	-	-	4.3	Provide for supply, installation, testing and commissioning of electric powered stirrer, vertical mount motor rating – Three phase 415v, 2.2KW, 905rpm, 50Hz, directly coupled to stainless stirring shaft, and stainless stirrer cross blade.	No.	2		
							Sub - total				
5.	Air Release Valve	5.0	Provide for supply, installation, testing and commissioning of air release valve of the following specifications.			5.0	Provide for supply, installation, testing and commissioning of air release valve of the following specifications.				
		5.1	Flanged 100mm double orifice. With cylinder body of 150mm diameter Material-stainless steel Working pressure PN16 Model: RB X 1601 Type: VENT-O-MAT	No.	30	5.1	Flanged 100mm double orifice. With cylinder body of 150mm diameter Material-stainless steel Working pressure PN16 Model: RB X 1601 Type: VENT-O-MAT	No.	30		
							Sub - total				
			Grand Total (VAT Inclusive)				Grand Total (VAT Inclusive)				

The tenders will be opened on the new date indicated above

THE AG. CHIEF EXECUTIVE OFFICER
KAKAMEGA COUNTY WATER AND SANITATION COMPANY
P.O.BOX 1189-50100 KAKAMEGA
KENYA
TEL: 056-2030355
Email to: kacwasco@gmail.com